

According to Section 4.29.1.b.xviii of ANSI Z21.10.3-2014 & CSA 4.3-2014 Standard for Gas-Fired Water Heaters, Volume III, Storage Water Heaters with Input Ratings Above 75,000 Btuh, Circulating and Instantaneous states:

“Use of cellular core PVC (ASTM F891), cellular core CPVC, or Radel[®] (polyphenylsulfone) in non-metallic venting systems is prohibited.”

The following link provides a summary of substantive changes:

[http://www.iapmostandards.org/Summary%20of%20Changes/Summary%20of%20Changes%20-%20ANSI%20Z21.10.3+CSA%204.3%20\(2013-2014\).pdf](http://www.iapmostandards.org/Summary%20of%20Changes/Summary%20of%20Changes%20-%20ANSI%20Z21.10.3+CSA%204.3%20(2013-2014).pdf)

U.S.A.

20 Commerce Park North, Bedford, NH 03110-6911
Tel: 603.669.5136 Fax: 888.889.3539 Toll Free: 800.654.5600

CANADA

452 Attwell Drive, Etobicoke, ON M9W 5C3
Tel: 416.679.0045 Fax: 416.679.0051